



FIRE UNDERWRITERS SURVEY

A SERVICE TO INSURERS AND MUNICIPALITIES

c/o CGI Information Systems and Management Consultants Inc., 90 Allstate Parkway, Markham, Ontario L3R 6H3
Telephone: (905) 474-0003 • Toll-free: 1-800-268-8080 • Fax: (905) 474-5604

RECEIVED
NOV 15 2005

November 08, 2005

Fire Chief Ted Bryan
Otonabee – South Monaghan Fire Department
P. O. Box 70
Keene, Ontario
K0L 2G0

Subject: **Superior Tanker Shuttle Accreditation**

Dear Chief Bryan:

The Fire Underwriters' Survey is pleased to give your municipality Superior Tanker Shuttle Accreditation. The test procedure was carried out on October 4th, 2005 with the undersigned present. The flow rate during the 2-hour test period averaged 2,384 litres per minute or 525 imperial gallons per minute.

Your team worked in a well co-ordinated and organized manner with proper supervision.

Regards,

Peter J. Rose, C.E.T., F.P.T.
Fire Protection Specialist